SANT VALVES SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

Tee

Product Description

Product Standard

As per IS:1239 (PART2): 1992 Screwed BSP Ends.
The carbon steel used in drop forged steel pipe fittings contains sulphur and phosphorus not exceeding 0.06% each.

End Connections

Screwed Female Ends conform to BSP as per BS21 / IS:554.
Other types of threads i.e. NPT can be given on request.


Test Pressure

IS:1239 (PART2) 1992-Pipe Fittings are tested to 1000 psig. (Hyd.)



Dimensions (in mm)

Nominal Size of Outlet	Minimum Length Center to Face (A)
8	22
10	24
15	32
20	35
25	43
32	51
40	52
50	64
65	76
80	89



Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com