SANT VALVES
SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

Socket

Product Description

Product Standard

As per IS:1239 (PART2): 1992 Screwed BSP Ends.
The carbon steel used in drop forged steel pipe fittings contains sulphur and phosphorus not exceeding 0.06% each.



End Connections


Screwed Female Ends conform to BSP as per BS21 / IS:554.
Other types of threads i.e. NPT can be given on request.

Test Pressure

IS:1239 (PART2) 1992-Pipe Fittings are tested to 1000 psig. (Hyd.)

Dimensions (in mm)

Nominal Size of Outlet	Minimum Outside Diameter (A)	Minimum Length (B)
8	18.5	27
10	22	28
15	27	37
20	32.5	39
25	39.5	46
32	49	51
40	56	51
50	68	60



Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com