SANT VALVES
SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

Concentric Reducer (Grooved) XGQT07

Product Description

Product Certification
UL Listed / FM Approved (EX 26523)

Material of Construction
Ductile Iron as per ASTM A536 Gr. 65 – 45 – 12

Pressure Rating
Test Pressure : 12.5 MPa
Max. Working Pressure : 2.5 MPa
Please note that as per FM 1920:2007 Sizes <= 150 mm are rated PN20 and > 150 mm are rated PN16

Nuts & Bolts
Heat Treated Carbon Steel as per ISO 898-1 Class 8.8

Finishing
Epoxy Red Paint RAL – 3000/3001

Dimensions (in mm)

Nominal Size	Nominal Size (Inch)	Pipe O.D.	L
50×25	2×1	60.3×33.7	60
50×32	2×1.1/4	60.3×42.4	64
50×40	2×1.1/2	60.3×48.3	64
65×25	2.1/2×1	76.1×33.7	64
65×32	2.1/2×1.1/4	76.1×42.4	64
65×40	2.1/2×1.1/2	76.1×48.3	64
65×50	2.1/2×2	76.1×60.3	64
80×25	3×1	88.9×33.7	64
80×32	3×1.1/4	88.9×42.4	64
80×40	3×1.1/2	88.9×48.3	64
80×50	3×2	88.9×60.3	64
80×65	3×2.1/2	88.9×76.1	64
100×50	4×2	114.3×60.3	76
100×65	4×2.2/1	114.3×76.1	76
100×80	4×3	114.3×88.9	76
125×50	5×2	139.7×60.3	102
125×65	5×2.1/2	139.7×76.1	102
125×80	5×3	139.7×88.9	102
125×100	5×4	139.7×114.3	102
150×50	6×2	165.1×60.3	102
150×65	6×2.1/2	165.1×76.1	102
150×80	6×3	165.1×88.9	102
150×100	6×4	165.1×114.3	102
150×125	6×5	165.1×139.7	102
200×50	8×2	219.1×60.3	127
200×65	8×2.1/2	219.1×76.1	127
200×80	8×3	219.1×88.9	127
200×100	8×4	219.1×114.3	127
200×125	8×5	219.1×139.7	127



Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com

Nominal Size	Nominal Size (Inch)	Pipe O.D.	L
200×150	8×6	219.1×165.1	127
250×100	10×4	273×114.3	135
250×125	10×5	273×139.7	135
250×150	10×6	273×165.1	135
250×200	10×8	273×219.1	135

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com