SANT VALVES SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

Cap XGQT06

Product Description

Product Certification
UL Listed / FM Approved (EX 26523)

Material of Construction
Ductile Iron as per ASTM A536 Gr. 65 – 45 – 12

Pressure Rating
Test Pressure : 12.5 MPa
Max. Working Pressure : 2.5 MPa
Please note that as per FM 1920:2007 Sizes <= 150 mm are rated PN20 and > 150 mm are rated PN16

Nuts & Bolts
Heat Treated Carbon Steel as per ISO 898-1 Class 8.8

Finishing
Epoxy Red Paint RAL – 3000/3001

Dimensions (in mm)

Nominal Size	Nominal Size (Inch)	Pipe O.D.	L
25	1	33.7	24
32	1.1/4	42.4	24
40	1.1/2	48.3	24
50	2	60.3	26
65	2.1/2	76.1	28
80	3	88.9	28
100	4	114.3	28
125	5	139.7	28
150	6	165.1	28
200	8	219.1	36
250	10	273.0	36

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com